ALL DOORS NSW

PO BOX 132 LEPPINGTON NSW 2170
Ph: 0417 975 669
Email: Sales@alldoorsnsw.com.au

FIRE SAFETY/INSTALLATION CERTIFICATE

Name of Owner: AUTO LIFT

Address of Building: HICKSON ROAD, ONE SYDNEY HARBOUR, BARANGAROO NSW 2000

We, All Doors NSW Pty Limited, certify that the installed fire rated roller shutter(s) specified in the current Fire Safety Schedule for the building (or part thereof) to which the certificate relates:

(a) has been assessed by a properly qualified person in accordance with Part 9 of the environmental Planning and Assessment Regulation 2000, and

(b) Was found, when it was assessed, to be capable of performing to at least the standard for which the fire rated roller shutter was originally designed and implemented

(c) The information contained in this statement is true and accurate to the best of my knowledge and belief

Assessment of Fire Rated Roller Shutters:

Description/Location of Installed Fire Rated Shutter
RS 01 located on basement level 1

Essential Fire Safety Measures

The relevant essential fire safety measures to the installed shutter are those specified in the most recent fire safety schedule, attached to one of the following:

- development consent for a change of building use,
- complying development certificate for the erection of a building or a change of building use,
- construction certificate for proposed building work, including work associated with a change of building use, or
- a fire safety order

Measures
Minutes: - /120 / - FRL (2hr Fire Rated Shutters)

Standard of Performance: B.C.A. CL C3.4,C3.5 AS 1905.2-2005
CSI REPORT NO. FCO-3381REVD

Date of Certificate: 31/01/2024

Signature:

Dominic Trimarchi – 20 Years' Experience

ALL DOORS NSW

PO BOX 132 LEPPINGTON NSW 2170
Ph: 0417 975 669
Email: Sales@alldoorsnsw.com.au

FIRE SAFETY/INSTALLATION CERTIFICATE

Name of Owner: AUTO LIFT

Address of Building: HICKSON ROAD, ONE SYDNEY HARBOUR, BARANGAROO NSW 2000

We, All Doors NSW Pty Limited, certify that the installed fire rated roller shutter(s) specified in the current Fire Safety Schedule for the building (or part thereof) to which the certificate relates:

(a) has been assessed by a properly qualified person in accordance with Part 9 of the environmental Planning and Assessment Regulation 2000, and

(b) Was found, when it was assessed, to be capable of performing to at least the standard for which the fire rated roller shutter was originally designed and implemented

(c) The information contained in this statement is true and accurate to the best of my knowledge and belief

Assessment of Fire Rated Roller Shutters:

Description/Location of Installed Fire Rated Shutter
RS 02 located on basement level 1

Essential Fire Safety Measures

The relevant essential fire safety measures to the installed shutter are those specified in the most recent fire safety schedule, attached to one of the following:

- development consent for a change of building use,
- complying development certificate for the erection of a building or a change of building use,
- construction certificate for proposed building work, including work associated with a change of building use, or
- a fire safety order

Measures
Minutes: - /120 / - FRL (2hr Fire Rated Shutters)

Standard of Performance: B.C.A. CL C3.4,C3.5 AS 1905.2-2005
CSI REPORT NO. FCO-3381REVD

Date of Certificate: 31/01/2024

Signature:

Dominic Trimarchi – 20 Years' Experience

ALL DOORS NSW

PO BOX 132 LEPPINGTON NSW 2170
Ph: 0417 975 669
Email: Sales@alldoorsnsw.com.au

FIRE SAFETY/INSTALLATION CERTIFICATE

Name of Owner: AUTO LIFT

Address of Building: HICKSON ROAD, ONE SYDNEY HARBOUR, BARANGAROO NSW 2000

We, All Doors NSW Pty Limited, certify that the installed fire rated roller shutter(s) specified in the current Fire Safety Schedule for the building (or part thereof) to which the certificate relates:

(a) has been assessed by a properly qualified person in accordance with Part 9 of the environmental Planning and Assessment Regulation 2000, and

(b) Was found, when it was assessed, to be capable of performing to at least the standard for which the fire rated roller shutter was originally designed and implemented

(c) The information contained in this statement is true and accurate to the best of my knowledge and belief

Assessment of Fire Rated Roller Shutters:

Description/Location of Installed Fire Rated Shutter
RS 03 located on basement level 1

Essential Fire Safety Measures

The relevant essential fire safety measures to the installed shutter are those specified in the most recent fire safety schedule, attached to one of the following:

- development consent for a change of building use,
- complying development certificate for the erection of a building or a change of building use,
- construction certificate for proposed building work, including work associated with a change of building use, or
- a fire safety order

Measures
Minutes: - /120 / - FRL (2hr Fire Rated Shutters)

Standard of Performance: B.C.A. CL C3.4,C3.5 AS 1905.2-2005
CSI REPORT NO. FCO-3381REVD

Date of Certificate: 31/01/2024

Signature:

Dominic Trimarchi – 20 Years' Experience