AUTO LIFT HUNTERS HILL 14610

Job #24629

ALL DOORS NSW PTY LTD
PO Box 132
LEPPINGTON
2179
NSW

Dominic Trimarchi

Quote: 15 Apr 2024
Quote is valid for 1 month

Client:
Auto Lift Garage Doors
Matt Volpatti
58-60 Gladesville Road
Hunters Hill
2110
New South Wales

CHECK TENSION

BOOKED
The garage door has developed a grinding cracking noise when operating. The righthand wall fixture of the roller has been bent away from the wall bending the steel support.
This is causing the spindle to not enter the roller at a correct 90-degree angle.

Site: Rob - 0408 204 312