

TO:	Any Doors & Gates Jaymee-Lee Pauley PO Box 132 LEPPINGTON 2179	Report No:	SR-OND21-09
		Date:	15 October 2021
		Reference:	OND21-09
		Order No:	

DESCRIPTION OF WORK PERFORMED

RE: DOMAYNE RUTHERFORD – SHUTTER DOOR – J/N 15318

- Fault find shutter door (aluminium extruded)
- Found shutter door had clips pulled off internals
- Adjusted top and bottom limits
- Re-secured clips back in place

The above works have been carried out in accordance with relevant Australian Standards and Codes of Practice.

RECOMMENDATIONS

- Continual servicing of door as required
- Ensure gear and equipment are not in the way of door when being closed

Technician Name: COREY BROWN

Technician Signature: 

Customer Name:

Customer Signature

THANK YOU FOR YOUR BUSINESS