

TO:	Any Doors & Gates Jaymee-Lee Pauley PO Box 132 LEPPINGTON 2179	Report No:	SR-AMJ22-02
		Date:	4 April 2022
		Reference:	AMJ22-02
		Order No:	

DESCRIPTION OF WORK PERFORMED

RE: HARVEY NORMAN BENNETTS GREEN – DOOR 7 & DOOR 4

DOOR 7

- Fault find door; damage by others; not shutting correctly
- Reposition truck steel ramp; pin shed under due to weather etc.

DOOR 4

- Extend cabling and remove unserviceable plug/socket
- Reconnect cabling; hard wired; test ran

The above works have been carried out in accordance with relevant Australian Standards and Codes of Practice.

RECOMMENDATIONS

DOOR 7

- Spoke to onsite personnel; things to look for and how to sort
- If persistent then replace curtain

DOOR 4

- Monitor; nothing further

Technician Name: COREY BROWN

Technician Signature: 

Customer Name:

Customer Signature

THANK YOU FOR YOUR BUSINESS

PHOTOGRAPHS



THANK YOU FOR YOUR BUSINESS