

<b>TO:</b>	Any Doors & Gates Jaymee-Lee Pauley PO Box 132 LEPPINGTON 2179	<b>Report No:</b>	SR-JFM23-18
		<b>Date:</b>	21 December 2022
		<b>Reference:</b>	
		<b>Order No:</b>	

### DESCRIPTION OF WORK PERFORMED

#### RE: REAR LOADING DOCK DOMAYNE RUTHERFORD

- Fault find door
- Re-greased guides
- Tightened chain; lubricated
- Cut off clamp; slat rubbing against plate; plate worn by 3mm (10mm thick originally)

The above works have been carried out in accordance with relevant Australian Standards and Codes of Practice.

### RECOMMENDATIONS

- Regular maintenance as per schedule
- Wash yearly; western door gets heavy rain/dust

**Technician Name:** COREY BROWN

**Technician Signature:** 

**Customer Name:**

**Customer Signature**

**THANK YOU FOR YOUR BUSINESS**

**PHOTOGRAPHS**



**THANK YOU FOR YOUR BUSINESS**