Able Door Services (NSW) Pty Ltd
ABN 90 097 064 527
507-509 Victoria Street
Wetherill Park NSW 2164

Tel. 02 9757 1877
Fax. 02 9757 1652
www.abledoors.com.au
doorservice@abledoors.com.au

CUSTOMER JOB NO. 29739

Site Details

Name	69 PITTWATER ROAD
Address	69 PITTWATER ROAD MANLY NSW 2095
Contact	CHRISTOPH
Telephone	0413 399 262
Mobile	
Email	

Customer Details

Name	ULTRALIFT GARAGE DOORS
Address	5 BRAMHALL AVENUE PUNCHBOWL NSW 2196
Contact	NIKKI
Telephone	9708 1444
Mobile	
Email	receptionist@ultralift.com.au

Work Requested

DOOR SERVICE REQUEST
JOB TAKEN: 13/12/2023
JOB COMPLETED: 14/12/2023

SHUTTER NOT CLOSING - FAULT CODE ON ATA READING PE BEAM

REALIGN PE BEAN & CHECK

GENERAL SERVICE TO CAR PARK SHUTTER
CHECK & TEST ALL OPERATIONS

CONTACT CHRISTOPH TO CONFIRM APPROX TIME

Schedule

Date Schedule	Date Performed	Scheduled Start	Scheduled Finish	Actual Start	Actual Finish	Total

Work to be Performed

Description	Required

Work Completed Notes

Materials Used

Description	Location	Used

Able Door Services (NSW) Pty Ltd
ABN 90 097 064 527
507-509 Victoria Street
Wetherill Park NSW 2164

Tel. 02 9757 1877
Fax. 02 9757 1652
www.abledoors.com.au
doorservice@abledoors.com.au

CUSTOMER JOB NO. 29739

The above works have been supplied and installed to my complete satisfaction.

Customer:

Print Name _____ Signature _____

The above works have been supplied and installed as per relevant Australian Standards.

Technician:

Print Name _____ Signature _____