Able Door Services (NSW) Pty Ltd
ABN 90 097 064 527
507-509 Victoria Street
Wetherill Park NSW 2164

Tel. 02 9757 1877
Fax. 02 9757 1652
www.abledoors.com.au
doorservice@abledoors.com.au

CUSTOMER JOB NO. 43084

Site Details	
Name	82 Allum Street Yagoona
Address	82 Allum Street Yagoona NSW 2199
Contact	SALIM
Telephone	0437954887
Mobile	
Email	

Customer Details	
Name	Bupa Villages and Aged Care Australia
Address	LEVELS 10-16 33 EXHIBITION STREET MELBOURNE VIC 3000
Contact	
Telephone	-
Mobile	
Email	damien.hardiman@bupa.com.au

Work Requested

SAME DAY SERVICE
JOB # 43084

JOB COMPLETE - 2/06/2025
TECH -

CAR PARK PANEL LIFT
PANEL LIFT WITH S-DRIVE MOTOR - STUCK IN OPEN POSITION
CLIENT DISCONNECTED HOLD OPEN (ACCESS CONTROL) AND DOOR DID STILL NOT OPERATE
PE BEAM WAS SLIGHTLY OUT OF ALIGNMENT - ADJUSTED PE BEAM - STILL DID NOT WORK
MOTOR BEEPS WHEN YOU TRY TO OPEN/CLOSE DOOR

DOOR APPROX 2700 MMH

CONTACT SALIM PRIOR AS HE WILL NEED TO CONTACT SOMEONE TO HAVE THE ACCESS CONTROL DISCONNECTED

Schedule

Date Schedule	Date Performed	Scheduled Start	Scheduled Finish	Actual Start	Actual Finish	Total

Work to be Performed

Description	Required

Work Completed Notes

Materials Used

Description	Location	Used

Able Door Services (NSW) Pty Ltd
ABN 90 097 064 527
507-509 Victoria Street
Wetherill Park NSW 2164

Tel. 02 9757 1877
Fax. 02 9757 1652
www.abledoors.com.au
doorservice@abledoors.com.au

CUSTOMER JOB NO. 43084

The above works have been supplied and installed to my complete satisfaction.

Customer:

Print Name _____ Signature _____

The above works have been supplied and installed as per relevant Australian Standards.

Technician:

Print Name _____ Signature _____