



Any Door & Gates Pty Ltd
 PO BOX 264
 Pendle Hill NSW 2145
 Tel: 1300 808 430
 Fax: 02 9863 7727
 sales@anydoor.com.au

ABN: 26 137 909 758

Tax Invoice No: 1118467

Issue Date: 12/1/2023

Due Date: 12/1/2023

Invoice To

All Doors (NSW) Pty Ltd
 Dom /Jayme

NSW

Reference

Cust On: 20038
 Job No: 21093
 Brighton Novotel
 Cnr grand parade and princess street

Description	Unit Charge	Total
Brighton Novotel Brighton Le Sands		
Please attend site the front sliding entrance doors to the building are not working corrcetly When they are on Exit - only guests are still able to get in Jean 9556 5133		
Detail of Work Completed		
1 Service Call Out Attended site as per service call out request Upon arrival of site inspected door found that when door is in lock or exit and you tap on the intercom which is located on the outside of the automatic door, the door may spring open, we tried this and it opened twice while onsite, have advised manager to contact security technician to rectify issue	\$295.00	\$295.00
		<hr/> \$295.00

Please send Remittance Advise via email to accounts@anydoor.com.au

Terms	Direct Debit	Cheque	Credit Card	Subtotal:	\$295.00
Full payment within	Commonwealth Bank BSB: 062 224	Cheques Payable to Any Door & Gates Pty Ltd	Call 1300 808 430	GST:	\$29.50
	Account: 102 05184	PO BOX 264 Pendle Hill NSW 2145	1.5% surcharge VISA + MasterCard + Bankcard	Total:	\$324.50



This payment claim is made under the Building and Construction Industry Security of Payment Act 1999 (NSW) or the Building and Concstruction Industry Security of payment Act 2002 (VIC), 2004 (QLD), 2009 (ACT) which ever applies. All Materials Remain the Property of Anydoor & Gates until Full Payment has been Received.



Any Door & Gates Pty Ltd
 PO BOX 264
 Pendle Hill NSW 2145
 Tel: 1300 808 430
 Fax: 02 9863 7727
 sales@anydoor.com.au

ABN:26 137 909 758

Task Sheet

Issue Date:9/1/2023

Details

Task: Repairs Brighton Novotel Brighton Le Sands
 Client: All Doors (NSW) Pty Ltd
 Requested: 9/1/2023 12:41PM
 Client Contact:

Reference

Job No: 21093
 Cust On: 20038
 Site: Brighton Novotel Brighton Le Sands

Description:

Please attend site the front sliding entrance doors to the building are not working corrcetly When they are on Exit - only guests are still able to get in Jean 9556 5133

REMARKS

Attended site inspected door found that when door is in lock or exit and you tap on the intercom which is located on the outside of the automatic door, the door may spring open, we tried this and it opened twice while onsite, have advised manager to contact security technician to rectify issue

Checklist	Completed	Y	N	N/A	Comments	GPS
Complainace Forms	9/1/2023 @ 2:55PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Arrived on Site	9/1/2023 @ 2:55PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Items Checked Item OK	9/1/2023 @ 3:11PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Items Adjusted Item OK	9/1/2023 @ 3:11PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Items Safe for use	9/1/2023 @ 3:11PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Site left clean & tidy	9/1/2023 @ 3:11PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Captured Signatures	9/1/2023 @ 3:11PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Completed By:

Completed: 9/1/2023 @ 3:11PM

Signatures:

Ken 9/1/2023

Mohammad 9/1/2023