



Any Door & Gates Pty Ltd
 PO BOX 264
 Pendle Hill NSW 2145
 Tel: 1300 808 430
 Fax: 02 9863 7727
 sales@anydoor.com.au

ABN: 26 137 909 758

Tax Invoice No: 1118452

Issue Date: 11/1/2023

Due Date: 11/1/2023

Invoice To

All Doors (NSW) Pty Ltd
 Dom /Jayme

NSW

Reference

Cust On: 30122022dom

Job No: 21042

11 Marco Avenue

Description	Revesby	Unit Charge	Total
11 Marco Avenue Revesby Please attend site auto door wouldn't open			
Detail of Work Completed			
1	Service Call Out Attended site as per service call out request Upon arrival of site inspected automatic sliding door Facing Marco ave, upon inspection of automatic sliding Door operator have found that control unit has Intermittent faults. This model of automatic door is extremely old and all parts are obsolete, have explained to store manager the situation with the automatic door and have advised her the door may fail again also it can get stuck in the closed position as the lock on this door is non compliant and requires power to unlock. Will submit quotation for further works, left door working but may fail again at any given time.	\$295.00	\$295.00
			\$295.00

Please send Remittance Advise via email to accounts@anydoor.com.au

Terms	Direct Debit	Cheque	Credit Card	Subtotal:	\$295.00
Full payment within	Commonwealth Bank BSB: 062 224 Account: 102 05184	Cheques Payable to Any Door & Gates Pty Ltd PO BOX 264 Pendle Hill NSW 2145	Call 1300 808 430 1.5% surcharge VISA + MasterCard + Bankcard	GST:	\$29.50
				Total:	\$324.50



This payment claim is made under the Building and Construction Industry Security of Payment Act 1999 (NSW) or the Building and Concstruction Industry Security of payment Act 2002 (VIC), 2004 (QLD), 2009 (ACT) which ever applies. All Materials Remain the Property of Anydoor & Gates until Full Payment has been Received.



Any Door & Gates Pty Ltd
 PO BOX 264
 Pendle Hill NSW 2145
 Tel: 1300 808 430
 Fax: 02 9863 7727
 sales@anydoor.com.au

ABN:26 137 909 758

Task Sheet

Issue Date:30/12/2022

Details

Task: Repairs 11 Marco Avenue Revesby
 Client: All Doors (NSW) Pty Ltd
 Requested: 30/12/2022 12:24PM
 Client Contact:

Reference

Job No: 21042
 Cust On: 30122022dom
 Site: 11 Marco Avenue
 Revesby

Description:

Please attend site auto door wouldn't open

REMARKS

Attended site and inspected automatic sliding door
 Facing Marco ave, upon inspection of automatic sliding Door operator have found that control unit has Intermittent faults. This model of automatic door is extremely old and all parts are obsolete, have explained to store manager the situation with the automatic door and have advised her the door may fail again and also it can get stuck in the closed position as the lock on this door is non compliant and requires power to unlock. Will submit quotation for further works, left door working but may fail again at any given time.

Checklist	Completed	Y	N	N/A	Comments	GPS
Complainace Forms	30/12/2022 @ 1:22PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Arrived on Site	30/12/2022 @ 1:22PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Items Checked Item OK	30/12/2022 @ 1:48PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Items Adjusted Item OK	30/12/2022 @ 1:48PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Items Safe for use	30/12/2022 @ 1:48PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Site left clean & tidy	30/12/2022 @ 1:48PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Captured Signatures	30/12/2022 @ 1:48PM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Completed By:

Completed: 30/12/2022 @ 1:48PM

Signatures:

Ranjeetha 30/12/2022

Mohammad 30/12/2022