

ALL DOORS NSW

Preventative Maintenance Check List

PO BOX 132 LEPPINGTON NSW 2170

Ph: 0417 975 669

Email: Sales@alldoorsnsw.com.au

JOB #	CMPT.
DATE:	30-1-23.
ADDRESS:	7 Smeaton Garage Rd. Smeaton Springs.
ARRIVAL TIME:	

SERVICE INSPECTION CHECK LIST Below is a check list of all items carried out during each visit. All items are checked for damage & fatigue

ROLLER SHUTTERS

Door 1.

ITEM	OK	REQUIRES ATTENTION, NOTE DETAIL
Check that track is secure	✓	
Check if track is worn & losing shape	/	
Check integrity of door, that there is no fatigue, broken weld etc.	/	
Check all stops or catches are secure and in correct position	/	
Check posts are firmly secured	/	
Check limits are set correctly	/	Reset Bottom Limit.
Check receiver and reception		
Check motor casing for cracks & operation	/	
Check PE Beam alignment and reflector	/	
Check PE Beam is sealed properly from insects	/	
Check chain tension	/	
Check motor is adjusted correctly	/	

GATES

Check operation of electronics		
Lubricate all moving parts		

TECHNICIAN SIGNATURE Debra Rose.

