Any Door & Gates Pty Ltd
PO BOX 264
Pendle Hill NSW 2145
Tel: 1300 808 430
Fax: 02 9863 7727
sales@anydoor.com.au

ABN: 26 137 909 758

Tax Invoice No: 1119552

Issue Date: 15/8/2023
Due Date: 15/8/2023

Invoice To

All Doors (NSW) Pty Ltd
Dom /Jayme

NSW

Reference

Cust On:

Job No: 22374
1-29 Bunn Street
Pyrmont

Description	Unit Charge	Total
1-29 Bunn Street Pyrmont front door not locking door - closer needs adjusting and mag lock needs a service **Detail of Work Completed**		
1 Service Call Out Attended site as per service call out request upon arrival of site inspected door as required found top pivot is worn out and will need replacing, transom closer in floor is very rusty, door will need to be removed. will quote further works	$295.00	$295.00
		$295.00

Please send Remittance Advise via email to accounts@anydoor.com.au

Terms	Direct Debit	Cheque	Credit Card
Full payment within	Commonwealth Bank	Cheques Payable to	Call 1300 808 430
	BSB: 062 224	Any Door & Gates Pty Ltd	
	Account: 102 05184	PO BOX 264	1.5% surcharge VISA +
		Pendle Hill NSW 2145	MasterCard + Bankcard

Subtotal:	$295.00
GST:	$29.50
Total:	$324.50

This payment claim is made under the Building and Construction Industry Security of Payment Act 1999 (NSW) or the Building and Concstruction Industry Security of payment Act 2002 (VIC), 2004 (QLD), 2009 (ACT) which ever applies. All Materials Remain the Property of Anydoor & Gates until Full Payment has been Received.

Any Door & Gates Pty Ltd
PO BOX 264
Pendle Hill NSW 2145
Tel: 1300 808 430
Fax: 02 9863 7727
sales@anydoor.com.au

ABN: 26 137 909 758

Task Sheet

Issue Date: 10/8/2023

Details

Task: Repairs 1-29 Bunn Street Pyrmont
Client: All Doors (NSW) Pty Ltd
Requested: 10/8/2023 12:38PM
Client Contact:

Reference

Job No: 22374
Cust On:
Site: 1-29 Bunn Street Pyrmont

Description:

front door not locking door - closer needs adjusting and mag lock needs a service

REMARKS

Attended site inspected door found top pivot is worn out and will need replacing, transom closer in floor is very rusty, door will need to be removed. will quote further works

Checklist	Completed	Y	N	N/A	Comments	GPS
Complainace Forms	10/8/2023 @ 2:19PM	X				
Arrived on Site	10/8/2023 @ 2:19PM	X				
Items Checked Item OK	10/8/2023 @ 9:52PM	X				
Items Adjusted Item OK	10/8/2023 @ 9:52PM	X				
Items Safe for use	10/8/2023 @ 9:52PM	X				
Site left clean & tidy	10/8/2023 @ 9:52PM	X				
Captured Signatures	10/8/2023 @ 9:52PM	X				

Completed By:

Completed: 10/8/2023 @ 9:52PM

Signatures:

Mohammad 10/8/2023

