# INVOICE

## C.S. Door Services

ABN/13818582601
8 Chelsea Garden Court Wattle Grove N.S.W 2173

Craig Stammers
0437 674 760
csdoorssrvices@hotmail.com

**Bill To**

All Doors N.S.W.
P.O. Box 1 Lurnea N.S.W. 2170

| | |
|---|---|
| **Invoice Num** | 653 |
| **Date** | 10 Sep 2024 |
| **Due Date** | 10 Oct 2024 |
| **Terms** | 29 days |

| Description | Quantity | Rate | Amount |
|---|---|---|---|
| 07/08/24 26027 Autolift 1081 Old Princes hwy Engadine General service to carpark panellift General service to loading dock shutter Test operation | 1 | $100.00 | $100.00 |
| 07/08/24 26004 United 1053 Old Princes hwy Engadine Panelbeat curtain Realign curtain Found to damaged to operate | 1 | $115.00 | $115.00 |
| 07/08/24 26128 Wharfside 2 West pde Manly Replace 1 long wheel Put back in track Test operation | 1 | $115.00 | $115.00 |
| 07/08/24 26088 Cityhome 13 Anglo rd Campsie Attempt to reset board and passcode Board wouldn't allow and kept opening Leave open and isolate | 1 | $115.00 | $115.00 |
| 07/08/24 26070 Autolift 19 Wilson st Botany General service to carpark shutter Test operation | 1 | $100.00 | $100.00 |
| 07/08/24 26107 Dominator 1356 Botany rd Botany Attend site Increase auto close to max (3mins) Found remote wouldn't code as faulty Test operation Notify Dominator | 1 | $130.00 | $130.00 |
| 07/08/24 26114 Newmans 2 Phillips rd Kogarah Install 2 motors Set motors Test operation | 1 | $170.00 | $170.00 |
| 08/08/24 26115 Ables 1/199 Auburn rd Yagoona Replace damaged equaliser bracket Refit spring Refit stop lugs Test operation No response from contact | 1 | $115.00 | $115.00 |
| 08/08/24 26121 Golden Seeds 168 Garden st Narrabeen Attend site Spoke with Vicki No fault with gate | 1 | $115.00 | $115.00 |
| 08/08/24 26100 Autolift 47 The Boulevard Cammeray Replace motor Wire in new motor & beams Test operation Supply 2 remotes | 1 | $220.00 | $220.00 |
| 08/08/24 25932 Rita 39 Wybalena rd Hunters Hill Replace damaged board Set limits Test operation | 1 | $160.00 | $160.00 |

| Description | Quantity | Rate | Amount |
|---|---|---|---|
| 09/08/24 25980 Strata Plus 38 Somerset Ave Narellan Attend site Found shutter showing no power Shutter self reset Possible house power or motor board fault Test operation of shutter | 1 | $115.00 | $115.00 |
| 09/08/24 26150 Pricewise 2/6 Cobar pl Gregory Hills Put rail back in guides Realign curtain Test operation | 1 | $115.00 | $115.00 |
| 09/08/24 26141 Thompsons 11 Mavis st Rooty Hill Attend site Found shutter closed Test operation Found no problem Test operation | 1 | $115.00 | $115.00 |
| 09/08/24 26144 Thompsons 29 Solent cct Baulkham Hills Reconnect push arm Increase force on motor Lubricate panellift Test operation | 1 | $115.00 | $115.00 |
| 09/08/24 26146 ADG 8 Wigram st Harris Park Attend site Found gate on the ground Couldn't move as too heavy Notify Joe and he said he'll sort it out Isolate motor | 1 | $115.00 | $115.00 |
| 09/08/24 26138 Advanced 48 Jacobs st Bankstown Add tension to roller Replace limits Reset limits Test operation | 1 | $115.00 | $115.00 |
| 09/08/24 26142 Dominator 826 Hume hwy Bass Hill General service to carpark shutter Found roller with broken springs Test operation | 1 | $115.00 | $115.00 |
| 09/08/24 26143 ADG 9 Murray Rose Ave Homebush Rejoin and tension spring Test operation | 1 | $115.00 | $115.00 |
| 09/08/24 25991 Ables 16 Birnie Ave Lidcombe Attempt to replace belt Found ewp not working properly Leave site | 1 | $115.00 | $115.00 |
| 09/08/24 26122 Dominator 5 Knox st Chippendale Adjust hand chain Found chain wheel wearing out Test operation | 1 | $115.00 | $115.00 |

Thank you for your business.

| | |
|---|---|
| Subtotal | $2,605.00 |
| GST (10%) | $260.50 |
| Total | $2,865.50 |
| Paid | $0.00 |
| **Balance Due** | **$2,865.50** |

## Payment instructions

**Bank transfer**

Bank Name: Commonwealth Bank
Beneficiary Name: Craig Stammers
Account Number: BSB 062424 ACCOUNT 10507113